



## Legislation Text

---

**File #:** 15-7607, **Version:** 1

---

**Case # 14-1628**

117 Duval LLC

117 Duval Street

FBC 1612.4 (ASCE 24-415) Unprotected enclosed structure below design flood elevation

Officer Scott Fraser

Certified Service: 3-23-2015

Initial Hearing: 5-27-2015

**In compliance November 4, 2015, request dismissal**

**Count 1:** In accordance with the City's requirements for participation in the National Flood Insurance Program (NFIP), the City's 2000 approval for construction of this commercial structure below the established NFIP flood level was contingent upon the installation and maintenance of approved floodproofing measures. These floodproofing measures no longer exist.