

Legislation Text

File #: 18-2529, Version: 1

Case # 16-1336 Douglas Whitman - Owner Suburban Propane 1317 Newton Street Sec. 14-31 Adopted construction codes Officer Beau Langford Certified Service: 5-30-2018 - Owner Certified Service: 5-30-2018 - Suburban Propane Initial Hearing: 7-25-2018

In compliance 8 Jun 2018; request dismissal

Count 1: Failure to secure propane tank against buoyancy in a FEMA designated AE-6 flood zone.